

**CITY OF HANSEN (PWS 5420027)**

**SOURCE WATER ASSESSMENT FINAL REPORT**

---

**May 19, 2006**



**State of Idaho  
Department of Environmental Quality**

**Disclaimer:** This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgment of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

## Table of Contents

<b>Executive Summary .....</b>	<b>iii</b>
<b>Section 1. Introduction - Basis for Assessment .....</b>	<b>1</b>
Level of Accuracy and Purpose of the Assessment.....	1
<b>Section 2. Conducting the Assessment .....</b>	<b>1</b>
General Description of the Source Water Quality .....	1
Defining the Zones of Contribution—Delineation .....	3
Identifying Potential Sources of Contamination.....	3
Contaminant Source Inventory Process.....	3
<b>Section 3. Susceptibility Analyses.....</b>	<b>5</b>
Hydrologic Sensitivity .....	5
Well Construction.....	5
Casing Diameter (inch).....	6
Casing Thickness.....	6
Casing Depth (feet).....	6
Potential Contaminant Sources and Land Use .....	6
Final Susceptibility Ranking .....	7
Susceptibility Summary.....	7
<b>Section 4. Options for Drinking Water Protection .....</b>	<b>7</b>
Characteristics of an Effective Drinking Water Protection Program .....	7
Focus on Long-Term Management Strategies.....	8
Assistance .....	8
<b>List of Acronyms and Definitions.....</b>	<b>9</b>
<b>References Cited .....</b>	<b>11</b>
<b>Appendix A: City of Hansen New Well Potential Contaminant Source Inventory.....</b>	<b>12</b>
<b>Appendix B City of Hansen New Well Susceptibility Analysis Worksheet.....</b>	<b>13</b>
<b>Report Index.....</b>	<b>15</b>
 <b>List of Figures</b>	
Figure 1, Geographic location of City of Hansen, PWS# 5420027. ....	2
Figure 2. City of Hansen New Well delineation and potential contamination sources.....	4
 <b>List of Tables</b>	
Table 1. City of Hansen well construction summary. ....	6
Table 2. Summary of City of Hansen New Well susceptibility evaluation.....	7
Table 3. City of Hansen New Well potential contaminant sources.....	12

## Executive Summary

The Environmental Protection Agency (EPA), under the Safe Drinking Water Act Amendments of 1996, is requiring the State of Idaho to assess the potential susceptibility to contamination of all public water systems (PWS).

The primary objective of these source water assessments is to provide information that public water systems can use to develop and implement local Drinking Water Protection Plans. By evaluating land use, system construction, and existing hydrologic and geologic conditions, systems are scored *high*, *moderate*, or *low* in terms of their susceptibility to contamination.

### What Was Assessed

This report evaluates New Well of the City of Hansen community water system (PWS No. 5420027), located just east of Twin Falls. The report titled “City of Hansen (PWS 5420027) Source Water Assessment Final Report” evaluates Wells #1, #2, and #3, and is available from DEQ upon request.

The system serves approximately 1000 people through 400 metered connections.

### How Susceptibility Scores Were Determined

Well susceptibility was scored in three areas:

- Well system construction
- Land use (type and amount) above the well’s aquifer. Land use can differ among wells, so separate scores are given for each of four types of contaminants:
  - Inorganic contaminants (IOCs), such as nitrates and arsenic
  - Volatile organic contaminants (VOCs), such as petroleum products
  - Synthetic organic contaminants (SOCs), such as pesticides
  - Microbial contaminants, such as bacteria
- Hydrologic and geologic conditions surrounding the well

### Scores for This Assessment

The final scores are as follows:

Drinking Water Source	Susceptibility Scores <sup>1</sup>									
	System Construction	Potential Contaminant Inventory/Land Use				Hydrologic Sensitivity	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
New Well	M	H	M	H	M	H	H	H	H	M

<sup>1</sup>H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility,

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Final susceptibility for New Well rated **high** for IOCs, VOCs, SOCs and **moderate** for microbial contaminants.

Hydrologic sensitivity for New Well rated **moderate susceptibility** and system construction rated **high susceptibility**. Based upon the number and type of potential contaminant sources found within three time-of-travel zones (zones indicating the number of years necessary for a particle of water to reach a well), land use rated **high susceptibility** for IOCs and SOCs, and **moderate susceptibility** for VOCs and microbial bacteria. See Table 3, page 12, for a complete listing of these sources.

### Summary of Laboratory Test Results for the System

A review of the system’s laboratory tests, using the Safe Drinking Water Information System State (SDWISS), revealed the following:

- No VOCs or SOCs have ever been detected in tested water.
- All of the IOCs detected in tested water have been below maximum contaminant levels set by the Environmental Protection Agency.

### How to Use These Results

This assessment is provided as information regarding City of Hansen’s drinking water and should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source.

DEQ strongly encourages each PWS to use the assessment report to develop a *Source Water Protection Plan*, which is a community-derived and proactive strategy to protect drinking water. Protection plans can help avoid drinking water contamination and reduce expensive treatment/replacement costs.

Protection plans can also help educate the served community. Many people have an “out of sight, out of mind” mentality, but improper disposal of certain chemicals can cause health impacts. For instance, concentrations of some contaminants, as small as a few parts-per-billion, can be higher than allowable limits.

These results should not be used as an absolute measure of risk, nor should they be used to undermine public confidence in the water system. A particular rating DOES NOT imply that any regulatory or legal actions will occur.

### Suggested Activities to Protect Your Drinking Water

Drinking water protection activities should first focus on correcting any deficiencies outlined in the *sanitary survey*. Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies, even though these strategies may not yield results in the near term.

System operators should do the following:

- Maintain a 50-foot radius (IDAPA 58.01.08.900.01) clear of all potential contaminants around the wellhead. If the pump house resides within this distance, it is important to keep the pump house clean and to not store disinfection chemicals or other chemicals there. The 50-foot buffer also reduces potential contamination related to chemical application or irrigation practices; the water system should restrict chemical application and activities near the wellhead.
- Identify and consider all possible sources of contamination not identified in this report, such as septic system effluent and document those sources to identify potential contaminant threats that could impact the City of Hansen drinking water wells.
- Correct any deficiencies included in the sanitary surveys—such as proper venting, drainage, and smooth nosed sample taps—as part of the water system’s drinking water protection efforts.
- Carefully monitor and deal with any contaminant spills within the well’s capture zone.
- Work with state and local agencies if the well’s capture zone(s) are outside the direct jurisdiction of your PWS.
- Locate new wells in areas with as few potential sources of contamination as possible, and ensure that each new site is reserved and protected.

A strong public education program should also be a primary focus of any drinking water protection plan, as most well capture zones contain at least some urban and residential land uses. Public education topics could include:

- Proper lawn and garden care practices
- Household hazardous waste disposal methods
- Proper care and maintenance of septic systems

- The importance of water conservation
- Best management practices

### **Resources and Assistance**

There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the EPA. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil and Water Conservation District, and the Natural Resources Conservation Service.

For assistance in developing protection strategies, contact DEQ's Twin Falls Regional Office or the Idaho Rural Water Association.

Twin Falls Regional DEQ Office                      (208) 736-2190

State DEQ Office    (208) 373-0502

Website: <http://www.state.id.us/deq>

Water suppliers serving fewer than 10,000 persons may contact Melinda Harper ([mlharper@idahoruralwater.com](mailto:mlharper@idahoruralwater.com)), Idaho Rural Water Association, at 1-208-343-7001 for assistance with drinking water protection (formerly wellhead protection) strategies.

## **SOURCE WATER ASSESSMENT FOR THE CITY OF HANSEN WATER SYSTEM IN TWIN FALLS COUNTY, IDAHO**

### **Section 1. Introduction - Basis for Assessment**

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are shown in Figure 1. The list of significant potential contaminant source categories used to develop the assessment is included as Table 3 in Appendix A.

#### **Level of Accuracy and Purpose of the Assessment**

The Idaho Department of Environmental Quality (DEQ) is required by the U.S. Environmental Protection Agency (EPA) to assess every public water system (PWS) source in Idaho for their relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area; sensitivity factors associated with the drinking water source and local aquifer characteristics. The resources and time available to accomplish assessments are limited. Therefore, an in-depth, site-specific investigation to identify each significant potential source of contamination for every public water supply system is not possible. **This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the PWS.**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. DEQ recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ also encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a drinking water protection program should be determined by the local community and be based upon its own needs and limitations. Wellhead or drinking water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

### **Section 2. Conducting the Assessment**

#### **General Description of the Source Water Quality**

City of Hansen, PWS# 5420027, is a community drinking water system located in Twin Falls County, approximately 8 miles east of the City of Twin Falls (Figure 1). The water system serves about 1000 people through 400 metered connections.

According to the State Safe Drinking Water Information System, no water sample results have been inputted into the database.

CITY OF HANSEN (PWS 5420027)S: SOURCE WATER ASSESSMENT FINAL REPORT




Figure 1, Geographic location of City of Hansen, PWS# 5420027.

## Defining the Zones of Contribution—Delineation

The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (zones indicating the number of years necessary for a particle of water to reach a pumping well) for water in the aquifer.

DEQ defined the zones of water contribution by using a refined computer model approved by the EPA in determining the 3-year (Zone IB), 6-year (Zone II), and 10-year (Zone III) TOT zones for water associated with the City of Hansen water system. The computer model used site-specific data, assimilated from a variety of sources, including well logs (when available) and hydrogeologic reports. Generally, ground water in this area flows in a northwesterly direction.

The City of Hansen Water System New Well is completed in basalt at depths between 74 feet below ground surface (bgs) and 553 feet bgs. It's delineation extends approximately 2 miles southeastward and encompasses an area up to approximately 0.75 miles wide (see Figure 2). The actual data used to determine the source water assessment delineation area is available from DEQ upon request.

## Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources.

The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of ground water contamination. The potential contaminant source locations within the delineation areas were obtained from existing databases and field surveys conducted by DEQ.

It is important to understand that a release may never occur from a potential source of contamination provided best management practices are used by the facility. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation.

There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, such as educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

## Contaminant Source Inventory Process

A two-phased contaminant inventory for New Well was conducted during May 2006. For reference, the well location, TOT zones, and potential contaminant sources are included in Figure 2 and Appendix A, Table 3.

- The first phase involved identifying and documenting potential contaminant sources within the water system's source water assessment area through the use of computer databases and geographic information system (GIS) maps developed by DEQ.
- The second phase, or *enhanced*, portion of the inventory involved contacting the water system. At the time of the enhanced inventory, no additional potential contaminant sources were identified.






Figure 2. City of Hansen New Well delineation and potential contamination sources.

### Section 3. Susceptibility Analyses

The susceptibility of the well to contamination was ranked as *high, moderate, or low* risk according to the following considerations:

- Hydrologic characteristics
- Physical integrity of the well
- Land use characteristics
- Potentially significant contaminant sources

The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgment. The following summaries describe the rationale for the susceptibility ranking. The susceptibility analysis worksheets have been included in Appendix B of this assessment.

#### Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors:

- Surface soil composition
- Material in the vadose zone (between the land surface and the water table)
- Depth to first ground water
- Presence of an aquitard (50 feet of impermeable materials above the producing zone of the well)

Slowly draining soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. Similarly, fine-grained sediments in the subsurface and a water depth of more than 300 feet protect the ground water from contamination.

The hydrologic sensitivity rated **high susceptibility** for New Well. According to the well log, an aquitard is not present above the well's producing zone, the vadose is composed of predominantly permeable materials, and the water table is less than 300 feet deep. Additionally, the Natural Resource Conservation Service classified area soils as *moderately- to well drained*.

#### Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system that can better protect the water. If the casing and annular seal both extend into a low permeability unit then the possibility of cross contamination from other aquifer layers is reduced and the system construction score goes down. If the highest production interval is greater than 100 feet below the water table, then the system is considered to have better buffering capacity. When information was adequate, a determination was made as to whether the casing and annular seals extend into low permeability units and whether current PWS construction standards are met.

The system construction scores rated **moderate susceptibility** for New Well.

The well is located outside of a 100-year floodplain, and the wellhead and surface seal are maintained. According to the well log, highest production does not come from more than 100 feet below static water levels, and both the casing and annular seal extend into low-permeability units.

According to the well log, a 12-inch casing (0.375 inches thick) and the bentonite annular seal were placed from +2 feet to 74 feet bgs and seated into a "black lava" unit. The well is an open hole from 74 feet bgs to its

completed depth at 553 feet bgs. The static water table was measured at 252 feet bgs. These well parameters were consolidated in Table 1.

Current PWS well construction standards can be more stringent than when a well(s) was constructed. The Idaho Department of Water Resources *Well Construction Standards Rules* (1993) require all PWSs to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works* (1997) during construction. Some of the regulations deal with screening requirements, aquifer pump tests, use of a down-turned casing vent, and thickness of casing. Table 1 of the *Recommended Standards for Water Works* (1997) lists the required steel casing thickness for various diameter wells.

Regulations for steel pipe thickness based on size of pipe

<u>Size of pipe (inches)</u>	<u>Thickness (inches)</u>
≤6	0.280
8	0.322
10	0.365
12-20	0.375

Well tests are required at the design pumping rate for 24 hours or until stabilized drawdown has continued for at least six hours when pumping at 1.5 times the design pumping rate.

Because the well's construction does not meet all current standards, the well was assessed an additional system construction point.

**Table 1. City of Hansen well construction summary.**

	Well Tag No.	Well Depth (feet)	Casing Diameter (inch)	Casing Thickness (inch)	Casing Depth (feet)	Water Table Depth (feet)	Screened Interval (feet)	Surface Seal Depth (feet)	Year Drilled	Well Log Avail.	IDWR/ DEQ Standards Met?
New Well	0036938	553	12	0.375	+2-74	252	74-553	74	2005	Yes	No

## Potential Contaminant Sources and Land Use

The potential contaminant sources and land use within the delineated zones of water contribution are assessed to determine each well's susceptibility. When agriculture is the predominant land use in the area, this may increase the likelihood of agricultural wastewater infiltrating the ground water system. Agricultural land is counted as a source of leachable contaminants and points are assigned to this rating based on the percentage of agricultural land.

In terms of potential contaminant sources and land use, New Well rated **high susceptibility** for IOCs (e.g., nitrates, arsenic) and SOCs (e.g., pesticides), and **moderate susceptibility** for VOCs (e.g., petroleum products) and microbial contaminants (e.g., bacteria).

The potential contaminant sources existing within the delineated capture zones include a transportation corridor, a canal, fertilizer wholesaler, and a decommissioned gas station. In addition, as the delineated area resides within an agriculturally developed area, agricultural chemicals were also considered in the scoring.

A complete list of the potential contaminant sources is included in Appendix A of this report (Table 3, page 12). The map shown in Figure 2 symbolizes the potential contaminant sources within the well's capture zones. The contaminant sources have been labeled with unique map identifiers (i.e., Map IDs) to reference with the corresponding list of potential contaminant sources in Appendix A.

## Final Susceptibility Ranking

Detection above a drinking water standard MCL, any detection of a VOC or SOC, or a confirmed microbial detection at the drinking water source will automatically give a high susceptibility rating, despite the land use of the area, because a pathway for contamination already exists. Additionally, potential contaminant sources within 50 feet of a well will automatically lead to a high susceptibility rating. Having multiple potential contaminant sources in the 0- to 3-year TOT zone (Zone IB) contributes greatly to the overall ranking.

## Susceptibility Summary

In terms of total susceptibility, New Well rated **high susceptibility** for IOCs and SOCs and **moderate susceptibility** for VOCs and microbial contaminants. The system construction rated **moderate susceptibility** and hydrologic sensitivity rated **high susceptibility**. The potential contaminant/land use scores were **high susceptibility** for IOCs and SOCs, and **moderate susceptibility** for VOCs and microbial sources. Refer to Table 2 for a summary of the City of Hansen New Well susceptibility evaluation.

**Table 2. Summary of City of Hansen New Well susceptibility evaluation.**

Drinking Water Source	Susceptibility Scores <sup>1</sup>									
	System Construction	Potential Contaminant Inventory/Land Use				Hydrologic Sensitivity	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
New Well	M	H	M	H	M	H	H	H	H	M

<sup>1</sup>H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility; IOC = Inorganic chemical, VOC = Volatile organic chemical, SOC = Synthetic organic chemical

It is unknown if there are major issues affecting water from New Well. According to SDWISS, no samples have been inputted into the database for this drinking water source.

## Section 4. Options for Drinking Water Protection

This source water assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

### Characteristics of an Effective Drinking Water Protection Program

An effective drinking water protection program is tailored to the particular drinking water protection area. A community with a fully developed drinking water protection program will incorporate many strategies.

Drinking water protection activities for City of Hansen should first focus on correcting any deficiencies outlined in the sanitary survey. The purpose of this survey is to inspect a water system every five years, to evaluate the physical condition of that water system’s components and its capacity.

It is important to maintain the well’s setback as an additional protection measure by keeping the pump house clean and not storing disinfection chemicals or other chemicals within this building.

The water system should restrict chemical application and irrigation practices that encroaches the wellhead.

Surface water sources located within 200 feet of the wellhead can be a potential source for contamination. Streams, canals, or ditches can transport many types of chemical contaminants that can move quickly, infiltrate soils, and possibly be drawn into ground water.

Any on-site septic systems should be identified and evaluated with respect to effluent discharge near the wellhead.

Protection of the area near the well is crucial, but all aspects of the water system are equally important: other deficiencies can include acquiring a certified Substitute Responsible in Charge Operator, having the ability to isolate the pressure tanks, and developing a written cross connection control program. Furthermore, developing a cross connection control plan will assist the water system in educating homeowners about back flow prevention devices to help reduce the possibility of used water entering distribution lines.

### **Focus on Long-Term Management Strategies**

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies, even though these strategies may not yield results in the near future. It is therefore recommended that City of Hansen consider developing a drinking water protection plan.

Important aspects of a drinking water protection plan include documenting and ranking the potential contaminant sources, outlining best management practices, and educating residents about their drinking water. Multiple resources are available to help communities develop a drinking water protection plan, including the Drinking Water Academy of the EPA. Working with the County, the local Soil Conservation District, and vicinity landowners will better inform the water system of chemicals that may be used, stored, or applied near the drinking water well.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (e.g., zoning, permitting) or non-regulatory in nature (e.g., good housekeeping, public education, specific best management practices). For assistance in protection strategies, please contact the DEQ Twin Falls Regional Office or the Idaho Rural Water Association (IRWA).

### **Assistance**

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

Twin Falls Regional DEQ Office (208) 736-2190

State DEQ Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact Melinda Harper (harperm@idahoruralwater.com) with IRWA, at (208) 343-7001, for assistance with drinking water protection strategies.

## List of Acronyms and Definitions

**AST (Aboveground Storage Tanks)** – Sites with aboveground storage tanks.

**bgs (Below Ground Surface)** – Depth below the surface of the ground.

**Business Mailing List** – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

**CERCLIS** – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as “Superfund” is designed to clean up hazardous waste sites that are on the national priority list (NPL).

**Cyanide Site** – DEQ permitted and known historical sites/facilities using cyanide.

**Dairy** – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few heads to several thousand head of milking cows.

**Deep Injection Well** – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of storm water runoff or agricultural field drainage.

**Enhanced Inventory** – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

**Floodplain** – This is FEMA data for the 100-year floodplains.

**Group 1 Sites** – These are sites that show elevated levels of contaminants and are not within a priority one area.

**Inorganic Priority Area** – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

**Landfill** – Areas of open and closed municipal and non-municipal landfills.

**LUST (Leaking Underground Storage Tank)** – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

**Mines and Quarries** – Mines and quarries permitted through the Idaho Department of Lands.)

**Nitrate Priority Area** – Area where greater than 25% of wells/springs show nitrate values above 5 mg/L.

**NPDES (National Pollutant Discharge Elimination System)** – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

**Organic Priority Areas** – These are any areas where greater than 25% of wells/springs show levels greater than 1% of the primary standard or other health standards.

**Recharge Point** – This includes active, proposed, and possible recharge sites on the Snake River Plain.

**RICRIS** – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

**Sanitary Survey** – An onsite review of the water source, facilities, equipment, operation, and maintenance of a public water system for the purpose of evaluating the adequacy of such source, facilities, equipment, operation, and maintenance for producing and distributing safe drinking water.

**SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities)** – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

**Toxic Release Inventory (TRI)** – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

**UST (Underground Storage Tank)** – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

**Wastewater Land Applications Sites** – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

**Wellheads** – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

**NOTE:** Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.



## References Cited

- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environment Managers, 1997.  
“Recommended Standards for Water Works.”
- Idaho Division of Environmental Quality Ground Water Program, October 1999. Idaho Source Water Assessment Plan.
- Idaho Department of Environmental Quality. 2003. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Environmental Quality. Safe Drinking Water Information System State(SDWISS).
- Idaho Department of Environmental Quality Spatial Database Engine (SDE).
- Idaho Department of Environmental Quality, 2005. Source Water Assessment Capture Zone Delineation, PWS #5420027 – Purple Sage Elementary (New Well)
- Idaho Department of Water Resources, 2006, Well Driller’s Report for City of Hansen. Permit D0036938.



## Appendix A: City of Hansen New Well Potential Contaminant Source Inventory

**Table 3. City of Hansen New Well potential contaminant sources.**

Map ID	Contaminant Description <sup>1</sup>	TOT Zone <sup>2</sup> (years)	Source of Information	Potential Contaminants <sup>3</sup>
1	Fertilizer Wholesaler	0-3YR	Database Search	IOC, SOC
2	Gas Station (decommissioned)	0-3YR	Database Search	VOC, SOC
	Union Pacific Railroad	0-3YR	Map	IOC, VOC, SOC, Microbial bacteria
	Twin Falls Main Canal	6-10YR	Map	IOC, VOC, SOC

<sup>1</sup> Refer To Potential Contaminant Inventory List Of Acronyms And Definitions

<sup>2</sup> TOT = Time-of-travel (in years) for potential contaminant to reach the wellhead

<sup>3</sup> IOC = Inorganic chemical; VOC = Volatile organic chemical; SOC = Synthetic organic chemical

## Appendix B City of Hansen New Well Susceptibility Analysis Worksheet

### Susceptibility Analysis Formulas

Intermediate Scoring for System Construction, Hydrologic Sensitivity, and Potential Contaminant/Land Use:

- 0 – 1 Low
- 2 – 4 Moderate
- 5 – 6 High

The final scores for the susceptibility analysis were determined using the following formulas:

- 1)  $\text{VOC/SOC/IOC Final Score} = \text{Hydrologic Sensitivity} + \text{System Construction} + (\text{Potential Contaminant/Land Use} \times 0.2)$
- 2)  $\text{Microbial Final Score} = \text{Hydrologic Sensitivity} + \text{System Construction} + (\text{Potential Contaminant/Land Use} \times 0.375)$

Final Susceptibility Scoring:

- 0 - 5 Low Susceptibility
- 6 - 12 Moderate Susceptibility
- $\geq 13$  High Susceptibility

# CITY OF HANSEN (PWS 5420027)S: SOURCE WATER ASSESSMENT FINAL REPORT

Ground Water Susceptibility Report    Public Water System Name: CITY OF HANSEN 5420027    Source: NEW WELL    Date: 4/19/2006

1. System Construction		SCORE			
	Drill Date	11/2/05			
	Driller's Log Available	YES			
	Sanitary Survey (if yes, indicate date of last survey)	NO			
	Well meet construction standards	NO	1		
	Wellhead and surface seal maintained	YES	0		
	Casing and annular seal extend to low permeability unit	YES	0		
	Highest production 100 feet below static water level	NO	1		
	Well located outside the 100 year flood plain	YES	0		
Total System Construction Score			2 (Moderate)		
2. Hydrologic Sensitivity					
	Soils are poorly to moderately drained	NO	2		
	Vadose zone composed of gravel, fractured rock or unknown	YES	1		
	Depth to first water > 300 feet	NO	1		
	Aquitard present with > 50 feet cumulative thickness	NO	2		
Total Hydrologic Score			6 (High)		
3. Potential Contaminant / Land Use - ZONE 1A			IOC Score	VOC Score	SOC Score    Microbial Score
	Land Use Zone 1A	IRRIGATED AGRICULTURE	2	2	2    2
	Farm chemical use high	YES	2	0	2    2
	IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO    NO
Total Potential Contaminant Source/Land Use Score - Zone 1A			4	2	4    2
Potential Contaminant / Land Use - ZONE 1B					
	Contaminant sources present (Number of Sources)	YES	3	2	3    1
	(Score = # Sources X 2)    8 Points Maximum		6	4	6    2
	Sources of Class II or III leacheable contaminants or	YES	5	2	2    2
	4 Points Maximum		4	2	2    2
	Zone 1B contains or intercepts a Group 1 Area	NO	0	0	2    0
	Land use Zone 1B	>50% Irrigated Agricultural Land	4	4	4    4
Total Potential Contaminant Source / Land Use Score - Zone 1B			14	10	16    6
Potential Contaminant / Land Use - ZONE II					
	Contaminant Sources Present	NO	0	0	0    0
	Sources of Class II or III leacheable contaminants or	YES	1	0	0    0
	Land Use Zone II	>50% Irrigated Agricultural Land	2	2	2    2
Potential Contaminant Source / Land Use Score - Zone II			3	2	2    2
Potential Contaminant / Land Use - ZONE III					
	Contaminant Source Present	YES	1	1	1    1
	Sources of Class II or III leacheable contaminants or	YES	1	1	1    1
	Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1    1
Total Potential Contaminant Source / Land Use Score - Zone III			3	3	3    3
Cumulative Potential Contaminant / Land Use Score			24 (H)	17 (M)	23 (H)    8 (M)
4. Final Susceptibility Source Score			13	11	13    11
5. Final Well Ranking			High	Moderate	High    Moderate

## Report Index

	<b>A</b>	definition, 3 protection measures, iv, 1, 7 protection strategy, 1	
agricultural wastewater, 6 aquifer, iii, 1, 3, 5 arsenic, iii, 6			<b>R</b>
	<b>B</b>	recharge, 9 risk levels, 5	
back flow prevention, 8 best management practices, 3, 8 Boise Regional DEQ Office, v, 8			<b>S</b>
	<b>C</b>	Safe Drinking Water Act, 1, 3, 9 SOCs, iii, iv, 6, 7 soil classification, 5 State DEQ Office, v, 8 susceptibility analysis, 5	
construction scores, 5 contaminant inventory, 3, 9 cross connection control program, iv, 8			<b>T</b>
	<b>D</b>	time-of-travel (TOT), 3	
disinfection chemicals, iv, 7			<b>U</b>
	<b>H</b>	U.S. Environmental Protection Agency (EPA), 1	
hydrologic sensitivity, 5, 7			<b>V</b>
	<b>I</b>	vadose zone, 5 VOCs, iii, iv, 6, 7	
Idaho Rural Water Association (IRWA), 8			<b>W</b>
	<b>L</b>	Well 1, iii, iv, 3, 4, 5, 6, 7, 12, 13 well construction, 5 well drilling information, 5	
land use, 1, 5, 6, 7 leachable contaminants, 6			<b>Z</b>
	<b>N</b>	zones of water contribution, 3	
Natural Resource Conservation Service, 5 nitrate, iv, 9 nitrates, iii, 6			
	<b>P</b>		
permeability, 5, 14 potential source of contamination			

Well Log

FORWARD WHITE COPY TO WATER RESOURCES

Form 238-7  
11/97 JGE

App 891237

IDAHO DEPARTMENT OF WATER RESOURCES

## WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
_____ 1/4	_____ 1/4	_____ 1/4	
Lat: _____		Long: _____	

1. WELL TAG NO. D 0036938

RECEIVED

DRILLING PERMIT NO. 836233

Other IDWR No. 47-4465

NOV-22-2005

## 2. OWNER:

Name City of Hansen

Department of Water Resources

Address P.O. Box 170

Southern Region

City Hansen

State ID Zip 83334

## 3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		W		E		S	
Twp. 10	North		or	South	X		
Rge. 18	East	X	or	West			
Sec. 24	NE 1/4		SW 1/4		SW 1/4		
Gov't Lot	County Twin Falls		Lat:		Long:		

Address of Well Site Park North of Highway

30 City Hansen

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

## 4. USE:

☐ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation  
☐ Thermal ☐ Injection ☒ Other City (municipal)

## 5. TYPE OF WORK: check all that apply

(Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

## 6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

## 7. SEALING PROCEDURES:

Seal/Filter Pack			AMOUNT		METHOD
Material	From	To	Sacks or	Brands	
bentonite	-7	74	39 sacks		grout pump
bentonite	-2	7	8 sacks		dry pour

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)Was drive shoe seal tested? ☐ Y ☒ N How?

## 8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
12	+2	74	.288	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe 2 Length of Tailpipe

## 9. PERFORATIONS/SCREENS:

☐ Perforations Method  
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

## 10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

252 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control

devices: steel pipe

## 11. WELL TESTS:

☐ Pump ☐ Baller ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
no return			

Water Temp. &lt;85

Bottom hole temp. &lt;85

Water Quality test or comments:

Depth first Water Encounter 276

## 12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water	Y	N
18	0	36	top soil & clay			
18	36	57	gray lava			
18	57	64	red ash & clay			
18	64	66	broken lava & clay			
18	66	100	black lava			
12	100	126	medium hard black lava			
12	126	130	black lava			
12	130	136	red & black cinders			
12	136	199	black lava			
12	199	207	broken black lava			
12	207	212	medium hard black lava			
12	212	231	black lava			
12	231		broken & cinders (no			
		236	returns)			
12	236	239	hard			
12	239	243	broken & cinders			
12	243	251	medium hard lava			
12	251	276	hard lava			
12	276	306	medium hard lava & breaks		X	
12	306	336	hard lava			
12	336	340	soft broken		X	
12	340	346	medium hard lava		X	
12	346	366	hard lava			
12	366	370	soft lava			
12	370	378	medium hard lava			
12	378	409	hard lava			
6	409	414	broken & loose rock		X	
12	414	491	hard lava			
12	491	493	soft broken lava		X	
12	493	529	medium hard like ash			
12	529	537	medium hard & breaks		X	
12	537	539	broken lava		X	
12	539	553	medium hard lava			

Completed Depth 553 per permit (Measurable)

Date: Started 10/27/2005

Completed 11/2/2005

## 13. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Eaton Drilling &amp; pump Service, Inc.

Firm No. 26

Firm Official

Date 11/15/2005

and

Driller or Operator

Date 11/15/2005

(Sign once if Firm Official &amp; Operator)